



Government Of West Bengal
Office Of The Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services
Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134

Memo no.:FSR/0125186210700009

Date: 22-02-2024

From:

Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services

To: ATRYEE COLLEGE OF EDUCATION

VILL-DANGI, P.O-KHIDIRPUR, P.S-BALURGHAT, DIST-DAKSHIN DINAJPUR, PIN-733103, JL.NO-87, KH.NO-613, PLOT NO-325, Under 5 no Bhatpara Gram Panchyat.

Sub: Issuance of Renewal Fire Safety Certificate for Existing construction of G+2 storied Educational Building under group of Educational in the name of ATRYEE COLLEGE OF EDUCATION at Premises-JL.NO-87, PLOT NO-325, KH.NO-613, Vill – DANGI, P.O-KHIDIRPUR, PS – BALURGHAT, Dist – DAKSHIN DINAJPUR, PIN-733103 UNDER 5 NO BHATPARA GRAM PANCHAYAT.

This is in reference to your application no. 0125191240700005 dated 15-02-2024 regarding the Issuance of Renewal Fire Safety Certificate for Existing construction of G+2 storied Educational Building under group of Educational in the name of ATRYEE COLLEGE OF EDUCATION at Premises-JL.NO-87, PLOT NO-325, KH.NO-613, Vill – DANGI, P.O-KHIDIRPUR, PS – BALURGHAT, Dist – DAKSHIN DINAJPUR, PIN-733103 UNDER 5 NO BHATPARA GRAM PANCHAYAT.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1) Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
- 2) Entrance / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
- 3) The interior finish decoration of the building shall be made with low flame spread materials conforming to the I.S Specification.
- 4) To eliminate risk of Fire Hazard, good house keeping both for insides and outsides of the building shall be strictly maintained.

- 5) Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly line above false ceiling and ducts.
- 6) The employee and security staffs shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
- 7) Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8) First aid fire fighting system shall be provided as per I.S specification.
- 9) Arrangement shall have to be made for regular checking, testing, and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
- 10) If require the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S conduit pipes continuously bonded to the earth.
- 11) All the pumps and detection system which are incorporated in the building shall be kept in auto mode round the clock.
- 12) The fire safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
- 13) The Fire safety certificates is valid for Three years and has to be renewed after three years from the date of issue of this letter. As per Govt. of West Bengal Vide Notification No- 629_L, Dated-17/04/2018
- 14) This certificates is to be obtained from the Director General, West Bengal Fire and Emergency Services regarding performance of all the fire safety arrangements and installing of the building.

Signature valid

Digitally Signed:
Name: SHIBA KUMAR SRMAN
Date: 22-Feb-2024 10:02
Reason: Approved
Location: West Bengal

Divisional Fire Officer, South Dinajpur
West Bengal Fire & Emergency Services